

N.C. DEPARTMENT OF HEALTH, ENVIRONMENT AND NATURAL RESOURCES

Groundwater Section

UNDERGROUND STORAGE TANK(S)

SITE NAME: NC National Guard - oms #7

REGULATED ☒

NONREGULATED ☒

	<u>YES</u>	<u>NO</u>
RELEASE CONFIRMED:	<u>          </u>	<u><input checked="" type="checkbox"/></u>
CLEAN-UP INITIATED: N/A	<u>          </u>	<u>          </u>
TANK(S) REMOVED:	<u><input checked="" type="checkbox"/></u>	<u>          </u>
RELEASE UNDER CONTROL:	<u><input checked="" type="checkbox"/></u>	<u>          </u>
CLEAN-UP COMPLETED:	<u>          </u>	<u>          </u>

TECHNICIAN: Michael B. Amosbaugh

DATE: 1 / 11 / 96

COMMENTS: CIS R&T I+R. No contamination  
Paragraph 2.1 type - < 1% product was in UST  
@ excavation. No product needed to be removed.

SITE NC NGuard - OMS # 7

REVIEW DATES 1-11-96

- ☒ USGS MAP
- ☒ BASE MAP
- ☒ ORIENTATION OF UST
- ☒ DIMENSIONS OF UST 8' x 16'
- ☒ VOLUME OF UST 6,000 gal
- ☒ MATERIAL STORED Heating Oil
- ☒ APPROPRIATE SAMPLE LOCATIONS
- ☒ DEPTH OF SAMPLE  $\approx$  10' above slab
- ☒ SIDE OR FLOOR SAMPLE
- ☒ DEPTH OF TANK BURIAL 2' BLS
- ☒ HOW SAMPLE WAS COLLECTED
- ☒ SAMPLES PRESERVED & TRANSPORTED
- ☒ TOOLS DECONTAMINATED
- ☒ TIME/DATE SAMPLE COLLECTED
- ☒ TIME/DATE LAB RECEIVED
- ☒ LAB RESULTS
- ☒ CHAIN-OF-CUSTODY
- ☒ ANALYSIS METHOD
- ☒ REFERENCE TO SAMPLING POINT ON MAP
- ☒ CORRECT # OF TANK SAMPLES
- ☒ PUMP/LINE SAMPLES *Lines Removed*
- ☒ WITHIN 14 DAY HOLDING TIME (or appropriate time)
- ☒ TANK DESTINATION
- ☒ N/A DISPOSITION OF SOIL
- ☒ ● CLOSURE DATE 8-11-95
- ☒ COMPLETE GW/UST-2 FORM
- ☒ CERTIFIED LABORATORY USED
- ☒ N/A SSE ACCEPTABLE
- ☒ ~~SEALED~~ SEALED BY LG or PE (CLOSURES 1/1/94 AND AFTER)
- ☒ No Sludge Destination
- ☒ GW-UST 12 (2-1-95)

- UST mounted on  
Cement pad, DOT Removed

- No apparent  
contamination  
Blue DOT